



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report. This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

Applicant: Nacional De Cobre S.A de C.V.
 Poniente 134
 No. 719 Colonia Industrial Vallejo
 Azcapotzalco 02300

Country: Mexico

Contact: Alonso Galarza Velazquez / Jose Luis Jimenez

Phone: +52 444 826 92 20 / +52 444 826

Fax:

Email: agalarza@elementia.com / jljimenezr@elementia.com

Party Authorized to Apply Mark: See following page(s)

Evaluation Center: Intertek (Coquitlam)

Control/Client Number: 173493

Authorized By: 
Thomas J. Patterson, Director of Certification

Intertek Testing Services NA, Inc.
 545 E. Algonquin Road, Ste H, Arlington Heights, IL 60005 USA
 Phone 847-439-5667 Fax 847-439-7320



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Testing Standard(s):	ASTM B819-00 (Reapproved 2006)
Product:	Nacional De Cobre - Seamless Copper Tubes for Medical Systems

ATM for Report 102049605COQ-001

ATM Issue Date: 01/27/2016

Listing Section(s): PRESSURE

CSI Code: 22 10 00 Plumbing Piping and Pumps

Description:

PRODUCT DESCRIPTION

The Nacobre ASTM B819 copper tubes are specially cleaned, straight lengths of seamless copper tubes. Table below summarizes products covered in this Specification.

Product	Temper	Type	Nominal Size (in.)
Seamless Copper Tube for Medical System, ASTM B819	H58	L	1/2, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3
Seamless Copper Tube for Medical System, ASTM B819	H58	K	3/8, 1, 2, 3

**Party(s) Authorized by
Manufacturer To Apply Mark:**

Nacional De Cobre S.A. de C.V.
(San Luis Potosi)
Avenida Promocion No. 200 Zona
Industrial

San Luis Potosi, 78395 , Mexico
Alonso Galarza Velazquez / Jose
Luis Jimenez
+ 52 444 826 92 20 / +52 444 826

agalarza@elementia.com /
jjjimenezr@elementia.com

**Party(s) Authorized by Other Parties To Apply
Mark:**

None